



Laboratory Ventilation Savings Analysis

for

Anywhere State University

New Laboratory Building

Boston, Ma (Using weather data from Boston, Massachusetts)

**Submitted by
Your Aircuity Rep**

Copyright 2010

Confidentiality Note: This document, and the software program that created it, is copyrighted and intended for use only by the individual or entity to which it is addressed and may contain information that is privileged, confidential, and exempt from disclosure under applicable law. If the reader is not the intended recipient or the employee or agent responsible for delivering the document to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please contact the sender immediately and destroy the material in its entirety, whether electronic or hard copy.

Aircuity Lab DCV Cashflow Savings Analysis



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep


Project Capital Costs	\$240,000
Diversity Savings & Dpt Sensors	\$0
Utility Incentive/Rebate	\$0
Net Capital Cost (Savings)	\$240,000

Energy Units Saved:
523,233 kWh saved annually
53,624 Therms saved annually
182 kW peak reduction via Max Bin Method

1st Year Savings	\$111,179
Simple Energy Payback	2.1 years

Cashflow Analysis

Year	Energy Savings	Net Recurring Costs	Annual Savings	Net Capital Costs	Net Annual Savings	Cumulative Savings
2011	\$111,179	\$0	\$111,179	(\$240,000)	(\$128,821)	(\$128,821)
2012	\$117,850	(\$21,012)	\$96,838		\$96,838	(\$31,982)
2013	\$124,921	(\$21,642)	\$103,279		\$103,279	\$71,296
2014	\$132,416	(\$22,292)	\$110,125		\$110,125	\$181,421
2015	\$140,361	(\$22,960)	\$117,401		\$117,401	\$298,822
2016	\$148,783	(\$23,649)	\$125,134		\$125,134	\$423,956
2017	\$157,710	(\$24,359)	\$133,351		\$133,351	\$557,308
2018	\$167,173	(\$25,089)	\$142,083		\$142,083	\$699,391
2019	\$177,203	(\$25,842)	\$151,361		\$151,361	\$850,752
2020	\$187,835	(\$26,617)	\$161,218		\$161,218	\$1,011,970
Totals	\$1,465,433	(\$213,463)	\$1,251,970	(\$240,000)	\$1,011,970	\$1,011,970
First year energy savings represent a 61% reduction from the base option.					NPV =	\$530,204
					IRR =	44.9%



Customer	Anywhere State University
Project	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

Annual CO2 Emission Rates for Power Generation in Massachusetts	US National Average
CO ₂ (lb/MWh)	1,205.6
	1345.1

Fossil Fuel Used	lb CO ₂ /MMBtu
Heating: Gas	116.39
Reheat: SameAsHeating	116.39
Other Fuel Type:	

Base Design Annual Emissions

Annual Energy Units	Equivalent MMBTUs	Equivalent MBTUs	CO ₂			Carbon			
			Lbs	Short Tons	Metric Tons	Lbs	Short Tons	Metric Tons	
Total kWh	1,059,730	3,617	3,616,857	1,277,657	639	579	348,452	174	158
Total Therms	66,077	6,608	6,607,656	769,065	385	349	209,745	105	95
Total Units		10,225	10,224,513	2,046,722	1,023	928	558,197	279	253

Proposed Design Annual Emissions

Annual Energy Units	Equivalent MMBTUs	Equivalent MBTUs	CO ₂			Carbon			
			Lbs	Short Tons	Metric Tons	Lbs	Short Tons	Metric Tons	
Total kWh	536,497	1,831	1,831,063	646,824	323	293	176,407	88	80
Total Therms	12,453	1,245	1,245,277	144,938	72	66	39,528	20	18
Total Units		3,076	3,076,340	791,762	396	359	215,935	108	98

Annual Lab DCV Emissions Savings

Annual Energy Units Saved	Equivalent MMBTUs	Equivalent MBTUs	CO ₂			Carbon			
			Lbs	Short Tons	Metric Tons	Lbs	Short Tons	Metric Tons	
Total kWh	523,233	1,786	1,785,794	630,833	315	286	172,045	86	78
Total Therms	53,624	5,362	5,362,379	624,127	312	283	170,217	85	77
Total Units		7,148	7,148,173	1,254,960	627	569	342,262	171	155

Saving 569 metric tons of CO₂ emissions is equivalent to:

- ✓ 69,420 gallons of gasoline burned (110 average cars).
- ✓ 155 metric tons of carbon.
- ✓ the annual CO₂ emissions from 48 average American households.

Aircuity Energy Cost Savings Summary



October 29, 2010


Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

	Base Design in CFM	Proposed Design in CFM	CFM Flow Savings
Average Day Airflow	46,667	25,494	21,173
Average Night Airflow	35,000	12,153	22,847
Average Airflow	39,167	16,917	22,249

Average Annual \$/CFM \$ 4.66 \$ 4.22

Energy Inflation Rate 6.0%

Year	Base Design Energy Costs (USD)	Proposed Design Energy Costs (USD)	Energy Savings (USD)	Cumulative Savings (USD)
2011	182,647	71,467	111,179	111,179
2012	193,606	75,755	117,850	229,030
2013	205,222	80,301	124,921	353,951
2014	217,535	85,119	132,416	486,367
2015	230,587	90,226	140,361	626,729
2016	244,423	95,639	148,783	775,512
2017	259,088	101,378	157,710	933,222
2018	274,633	107,461	167,173	1,100,395
2019	291,111	113,908	177,203	1,277,598
2020	308,578	120,743	187,835	1,465,433
10 Yr Savings	\$ 2,407,430	\$ 941,997	\$ 1,465,433	\$ 1,465,433



Aircuity Savings Analysis Base Data & Assumptions



October 29, 2010

Customer Name	Anywhere State University		
Project Name	New Laboratory Building		
City	Boston, Ma	Weather Station:	Massachusetts, Boston
Submitted by	Your Aircuity Rep		

Building & Financial Assumptions		Baseline & Proposed Design Data			
Number of Zones	50	Zone Types			
Avg Zone Area (sq. ft.)	700	Normal Activity, Low Load	Moderate Activity, Medium Load	High Activity, High Load	
Total sq. ft. (calculated)	35,000	80%	15%	5%	
Avg Ceiling Height	10	Number of Zones	39	8	3
Total # of Fume Hoods	10	Avg Peak Watts/ft ² (Day)	4.0	6.0	10.0
Avg FH Max CFM	800	Avg Watts/ft ² (Day)	3.0	4.5	7.5
Avg FH Min CFM	160	Avg Peak W/ft ² Nite	2.0	3.0	5.0
Avg Day FH Sash Opening	60% Open	Avg Watts/ft ² Nite	1.2	1.8	3.0
Avg Nite FH Sash Opening	30% Open	Day ACH	8	8	8
Annual Inflation Rate	3%	Night ACH	6	6	6
Energy Inflation Rate	6%	Proposed Variable Ventilation Rates			
Hurdle Rate	8%	Normal Day ACH	4	4	4
Incentive/Rebate \$/kWh	\$ -	Normal Night ACH	2	2	2
Incentive/Rebate \$/Therm	\$ -	High Vent Max ACH	12	12	12
Incentive/Rebate \$/kW	\$ -				
Find Utility Rebates and Tax Incentives					

Energy Cost & HVAC System Assumptions	
Cooling Method	Electric
Heating Method	Gas
ReHeat Method	SameAsHeating
Occ Cooling Set Point	74 °F
Occ Heating/Reheat Set Point	74 °F
Electric \$/kWh	\$ 0.1100
Chilled Water \$/Ton-Hour	\$ 0.1817 (Not used)
Gas/Oil/Other Fuel \$/Therm	\$ 1.0000
Steam \$/1,000 lb.	\$ 12.4000 (Not used)
UnOcc Cooling Set Point	74 °F
UnOcc Heating/Reheat Set Point	74 °F
Evaporative Cooling	None
(Triggers Wet Bulb Recalc)	
SA Temp	55 °F
Proposed Room Cooling Method	VAV Air System
Base Design Room Cooling Method	SameAsProposed
COP of Refrigeration System	3.0
Heating Efficiency	80%
OA Humidification	None
Humidification RH Set Point	45%
Heat Recovery System Type	Sensible Only
Heat Recovery Efficiency	50%
Heat Recovery Installed Price	\$ 165,710
Annual Heat Recovery Costs	\$ 3,300
Extra Static from Heat Recovery	0.75 in.

Fan System Assumptions & Data	
Supply Fan Discharge Static - no HR	5.00 in w.c.
Supply Fan Efficiency	70%
Exhaust Fan Inlet Static - no HR	4.50 in w.c.
Exhaust Fan Efficiency	60%
Exhaust Fan Control Strategy:	Staged Fans w/ Bypass Damper
Number of Exhaust Fans	4

Capital Cost Savings & Diversity Assumptions (Diversity not included)			
Include Diversity Savings	No	Baseline \$/CFM	Diversity %
Design %	99.90%	\$8.77	Cooling System 100%
Baseline CFM/Ton of Cooling	205	\$2.50	Heating System 100%
\$/Ton: Cooling System	\$ 1,800	\$1.00	Reheat System 100%
Subtract Cost of Dewpoint Sensors	No	\$1.25	Exhaust Fan 100%
*Dewpoint Sensor Cost Installed	\$ 1,500	\$4.50	Supply AHU 100%
Aircuity Installed System Price	\$ 240,000 (from ONE)	\$0.15	AHU VFDs 100%
Annual Aircuity Costs	\$ 20,400 (from ONE)	\$0.45	Ductwork 100%
Years of Annual Services in System Price	1.0 Years	\$18.62	Total Base HVAC

Release Version: 1.99T6 Beta Vers. Release Date: October, 2010

Occupancy Schedule



September 15, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

Hour	Sun	Mon	Tue	Wed	Thu	Fri	Sat
12 to 1 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
1 to 2 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
2 to 3 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
3 to 4 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
4 to 5 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
5 to 6 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
6 to 7 AM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
7 to 8 AM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
8 to 9 AM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
9 to 10 AM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
10 to 11 AM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
11 to Noon	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
12 to 1 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
1 to 2 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
2 to 3 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
3 to 4 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
4 to 5 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
5 to 6 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
6 to 7 PM	UnOcc	Occ	Occ	Occ	Occ	Occ	UnOcc
7 to 8 PM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
8 to 9 PM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
9 to 10 PM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
10 to 11 PM	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc
11 to Midnight	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc	UnOcc

	Occ Hours	UnOcc Hours	Off Hours	Occ Hours Percent	UnOcc Hours Percent
0-6	0	42	0	0%	100%
7-12	25	17	0	60%	40%
13-18	30	12	0	71%	29%
19-24	5	37	0	12%	88%
Total	60	108	0	36%	64%

Aircuity CFM Savings Summary



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

CFM Comparisons

	Base Calculated CFM	Proposed Calculated CFM	CFM Differences	% Differences
Total Fume Hood Maximum CFM	8,000	8,000	0	0%
Total Fume Hood Minimum CFM	1,600	1,600	0	0%
Estimated Total FH Avg CFM - Day	4,800	4,800	0	0%
Estimated Total FH Avg CFM - Night	2,400	2,400	0	0%
Avg Peak Cooling CFM - Day	27,137	29,709	2,572	9%
Avg Cooling CFM - Day	20,353	20,353	0	0%
Avg Peak Cooling CFM - Night	13,569	14,697	1,129	8%
Avg Cooling CFM - Night	8,141	8,141	0	0%
Day Average ACH CFM	46,667	23,987	(22,680)	-49%
Night Average ACH CFM	35,000	11,818	(23,182)	-66%
<hr/>				
Avg Peak CFM - Day	47,346	30,539	(16,807)	-35%
Average CFM - Day	46,667	25,494	(21,173)	-45%
<hr/>				
Avg Peak CFM - Night	35,000	15,660	(19,340)	-55%
Average CFM - Night	35,000	12,153	(22,847)	-65%

Ventilation CFMs and ACHs


	System CFM	Avg. Zone CFM
2 ACH	11,666	233
3 ACH	17,500	350
4 ACH	23,333	466
5 ACH	29,166	583
6 ACH	35,000	700
7 ACH	40,833	816
8 ACH	46,666	933
9 ACH	52,500	1,050
10 ACH	58,333	1,166
11 ACH	64,166	1,283
12 ACH	70,000	1,400
13 ACH	75,833	1,516
14 ACH	81,666	1,633
15 ACH	87,500	1,750
16 ACH	93,333	1,866

Aircuity Average Airflow Savings Comparison



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep



Heat Recovery & Lab DCV Cashflow Savings Analysis



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

Heat Recovery Capital Costs in \$	106,886
Relative Lab DCV Costs in \$	0
Utility Incentive/Rebate in \$	0
Net Cost Impact on HVAC Capacity	(14,528)
Net Capital Cost over Baseline in \$	92,358

Energy Units Saved:
-77,769 kWh saved annually
16,360 Therms or 1,726 GigaJ saved annually
3 kW peak reduction calculation via Max Bin Method

Baseline System:	LabDCV Only
Proposed System:	HR & LabDCV
Include Impacts on HVAC 1st Cost	Yes


System	Energy Costs:	HVAC 1st Cost:
Baseline	\$ 74,587	\$ 583,157
Proposed	\$ 66,781	\$ 568,629

1st Yr Savings over Baseline	\$ 7,806
Simple Energy Payback	9.2 years

	Primary HR	Secondary HR
HR Equipment:	Glycol Coils	None
HR Efficiency	0.5	

Cashflow Analysis of Using Heat Recovery & Lab DCV vs. a Baseline of Lab DCV Only in USD

Year	Energy Savings in USD	Net Recurring Costs in USD	Annual Savings in USD	Net Capital Costs in USD	Net Annual Savings in USD	Cumulative Savings in USD
2011	7,806	(3,300)	4,506	(92,358)	(87,853)	(87,853)
2012	8,274	(3,399)	4,875		4,875	(82,978)
2013	8,771	(3,501)	5,270		5,270	(77,708)
2014	9,297	(3,606)	5,691		5,691	(72,017)
2015	9,855	(3,714)	6,140		6,140	(65,877)
2016	10,446	(3,826)	6,620		6,620	(59,256)
2017	11,073	(3,940)	7,132		7,132	(52,124)
2018	11,737	(4,059)	7,678		7,678	(44,446)
2019	12,441	(4,180)	8,261		8,261	(36,185)
2020	13,188	(4,306)	8,882		8,882	(27,303)
Totals	\$ 102,886	\$ -37,831	\$ 65,055	\$ -92,358	\$ -27,303	-27,303
First year energy savings represent a 4% reduction from the base option.					NPV =	\$ -46,975
					IRR =	-5.4%



Aircuity Diversity Savings Analysis



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

Base Design

The base design has a peak cooling requirement of 27,100 CFM (with a peak average of 4.7 watts per sq foot);
 A base occupied minimum ventilation level requirement of 46,700 CFM (8 ACH);
 And a base unoccupied minimum ventilation level requirement of 35,000 CFM (6 ACH).
 An estimated maximum fume hood flow rate of 4,800 CFM (with 60% fume hood diversity factor);

Proposed Design

The peak cooling and estimated maximum fume hood flows are the same as in the base design.
 With 50 zones, 99.9000% of the time there will be 4 or fewer zones at the proposed max 12 ACH,
 and 99.9000% of the time there will be 46 or more zones at the proposed normal 4 ACH.
 The proposed occupied minimum ventilation rate is 24,000 CFM (4 ACH);
 The proposed unoccupied minimum ventilation rate is 11,800 CFM (2 ACH).

	Base Design	Proposed
Total number of Zones	50	50
99.9000th percentile of zones at normal Occ ACH	N/A	46
Number of zones at max ACH (Occ.)	N/A	4
Occupied Normal Zone ACH	8 ACH	4 ACH
Unoccupied Normal Zone ACH	6 ACH	2 ACH
Proposed Max Zone ACH	N/A	12 ACH
Occupied Normal Zone ACH in CFM	933	467
Unoccupied Normal Zone ACH in CFM	700	233
Proposed Max Zone ACH in CFM	N/A	1,400
System CFM Per Ton of Cooling	205	205
HVAC Capital Cost per CFM in Units of \$/CFM	18.62	18.62
Cooling System Capacity Requirements in Tons	231	149

Proposed Design Diversity Flow in CFM

	Base Design	Proposed	Peak CFM Saved
Avg Max Flow for Normal Activity Zones	36,400	21,112	15,288
Avg Max Flow for Moderate Activity Zones	7,467	5,905	1,562
Avg Max Flow for High Activity Zones	3,479	3,522	-43
EXPECTED PEAK CFM	47,346	30,539	16,807

Zone diversity on this project results in a 35% peak airflow savings with up to \$ 313,000 of project first cost savings due to the reduction in size of the HVAC mechanical system.

The payback in this analysis does not include the diversity described above.

Aircuity First Cost (Diversity) Savings Summary




October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

HVAC System Component	Base Design			Proposed Design with 100% Diversity			
	USD/CFM	Based on Max CFM Flow of:	System Cost in USD	% of Diversity Savings	Based on Max CFM Flow of:	System Cost in USD	First Cost Savings over Base Design
Cooling System	\$ 8.77	47,346	415,212	100%	30,539	267,820	147,392
Heating System	\$ 2.50	47,346	118,364	100%	30,539	76,347	42,017
Reheat System	\$ 1.00	47,346	47,346	100%	30,539	30,539	16,807
Exhaust Fan(s)	\$ 1.25	47,346	59,182	100%	30,539	38,174	21,009
Supply AHU(s)	\$ 4.50	47,346	213,056	100%	30,539	137,425	75,631
AHU VFDs	\$ 0.15	47,346	7,102	100%	30,539	4,581	2,521
Ductwork	\$ 0.45	47,346	21,306	100%	30,539	13,743	7,563
Total HVAC System	\$ 18.62		881,568			568,629	\$ 312,939

Proposed Design w/Partial (Selected) Diversity					
HVAC System Component	USD/CFM	% of Diversity Savings	Based on Max CFM Flow of:	System Cost in USD	First Cost Savings over Base Design
Cooling System	\$ 8.77	100%	30,539	267,820	147,392
Heating System	\$ 2.50	100%	30,539	76,347	42,017
Reheat System	\$ 1.00	100%	30,539	30,539	16,807
Exhaust Fan(s)	\$ 1.25	100%	30,539	38,174	21,009
Supply AHU(s)	\$ 4.50	100%	30,539	137,425	75,631
AHU VFDs	\$ 0.15	100%	30,539	4,581	2,521
Ductwork	\$ 0.45	100%	30,539	13,743	7,563
Total HVAC System	\$ 18.62			568,629	\$ 312,939

HVAC Mechanical System First Cost Comparison



Aircuity & Photovoltaics (Solar Energy)Technology Comparison

October 29, 2010

Customer	Anywhere State University
Project	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

**The Aircuity system has about the same carbon impact as a 797 kW solar panel.
 The Aircuity system will save about the same electrical energy generated by a 410 kW solar panel.
 The Aircuity system will cost approximately 4.3% of a solar panel with the same carbon impact.
 The Aircuity system payback is about 16.1 times better than solar panels, even w/ incentives & credits.**

Figures of Merit	Solar Panels (797 kW)	OptiNet	OptiNet to Solar Factor
Metric tons of CO ₂ saved	569	569	1.0
kWh Power Generated/ Saved	1,040,904	523,233	0.5
Gas Savings in therms	0	53,624	N/A
Total equivalent MBTU saved	3,553	7,148	2.0
Annual Savings in USD	114,499	111,179	0.97
Installed Cost in USD	5,576,130	240,000	23.2
Simple payback in years	48.7	2.2	22.6
Simple payback yrs w/ incentive for Public, Gov, Edu	38.3	1.5	26.3
Simple payback w/ Ren. Fed & State Credits - Bus.	23.4	1.5	16.1
Area of Installation in square feet	7,404	15.0	494
Equipment weight in pounds	126,465	450	281

Assumptions:	Value	
Electric Power Costs USD/kWh (from Assumptions)	0.110	USD/kWh
Gas Heating Costs per therm (from Assumptions)	1.000	USD
Annual Solar kWh hours per kW (Massachusetts, Boston)	1,307	
CO ₂ lb/kWh (Massachusetts, Boston)	1.2056	
Carbon lb to MBTU Equivalent (Gas)	#N/A	
Installed Cost per kWh: Large Installation (>10 kW) (1)	7.0	USD/kWh
Solar Array Equipment-only USD/W	4.8	USD/W
OptiNet Installed Cost	240,000	USD
OptiNet Equipment weight (lb/system)	450.0	
OptiNet Equipment space used in sq feet	15.00	
Utility Energy Efficiency Incentive - USD/kWh, ≥ 1 year payback (3)	0.15	USD/kWh
State Renewable Energy incentive - USD/kW of Solar PV capacity(3)	1.00	USD/kW
Utility Solar Energy Incentive - USD/kW of Solar PV capacity(3)	0.50	USD/kW
Federal Tax Renewable Credit % off (2)	30%	
State Tax Renewable Credit % up to USD25,000 (3)	0.4%	
Watts per square foot - Solar Array	107.58	
OptiNet kWh savings	523,233	
OptiNet Gas Savings in Therms	53,624	
Solar Array Size with Same Carbon Impact Savings as OptiNet	797	kW
Solar Array Size w/ Same Electrical Savings as OptiNet System	410	kW
Installed weight of Solar Panels in (lbs/ft ²)	17.08	

- (1) www.srpnet.com/environment/earthwise/solarbiz.aspx
- (2) http://dsireusa.org/library/includes/incentive2.cfm?Incentive_Code=US02F&State=federal¤tpageid=1&ee=1&re=1
- (3) <http://dsireusa.org>

Aircuity 5-Year Life Cycle Cost Analysis



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

	Base Design	Aircuity	Aircuity Savings
Aircuity First Cost	\$0	\$240,000	(\$240,000)
Diversity Savings	\$0	\$0	\$0
Rebate & Incentives	\$0	\$0	\$0
Adjustments to First Cost	\$0	\$0	\$0
Net First Cost	\$0	\$240,000	(\$240,000)
Year 1 Energy Cost	\$182,647	\$71,467	\$111,179
Year 2 Energy Cost	\$193,606	\$75,755	\$117,850
Year 3 Energy Cost	\$205,222	\$80,301	\$124,921
Year 4 Energy Cost	\$217,535	\$85,119	\$132,416
Year 5 Energy Cost	\$230,587	\$90,226	\$140,361
Total 5 Year Energy Cost	\$1,029,597	\$402,868	\$626,729
Year 1 Maintenance Cost		\$0	\$0
Year 2 Maintenance Cost		\$21,012	(\$21,012)
Year 3 Maintenance Cost		\$21,642	(\$21,642)
Year 4 Maintenance Cost		\$22,292	(\$22,292)
Year 5 Maintenance Cost		\$22,960	(\$22,960)
5 Year Maintenance Cost	\$0	\$87,906	(\$87,906)
Total 5 Year Operation Cost	\$1,029,597	\$490,775	\$538,822
5 Year Cost of Ownership	\$1,029,597	\$730,775	\$298,822
Avg. Cost of ownership per year	\$102,960	\$73,077	\$29,882

Aircuity 10-Year Life Cycle Cost Analysis



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

	Base Design	Aircuity	Aircuity Savings
Aircuity First Cost	\$0	\$240,000	(\$240,000)
Diversity Savings	\$0	\$0	\$0
Rebate & Incentives	\$0	\$0	\$0
Adjustments to First Cost	\$0	\$0	\$0
Net First Cost	\$0	\$240,000	(\$240,000)
Year 1 Energy Cost	\$182,647	\$71,467	\$111,179
Year 2 Energy Cost	\$193,606	\$75,755	\$117,850
Year 3 Energy Cost	\$205,222	\$80,301	\$124,921
Year 4 Energy Cost	\$217,535	\$85,119	\$132,416
Year 5 Energy Cost	\$230,587	\$90,226	\$140,361
Year 6 Energy Cost	\$244,423	\$95,639	\$148,783
Year 7 Energy Cost	\$259,088	\$101,378	\$157,710
Year 8 Energy Cost	\$274,633	\$107,461	\$167,173
Year 9 Energy Cost	\$291,111	\$113,908	\$177,203
Year 10 Energy Cost	\$308,578	\$120,743	\$187,835
Total 10 Year Energy Cost	\$2,407,430	\$941,997	\$1,465,433
Year 1 Maintenance Cost		\$0	\$0
Year 2 Maintenance Cost		\$21,012	(\$21,012)
Year 3 Maintenance Cost		\$21,642	(\$21,642)
Year 4 Maintenance Cost		\$22,292	(\$22,292)
Year 5 Maintenance Cost		\$22,960	(\$22,960)
Year 6 Maintenance Cost		\$23,649	(\$23,649)
Year 7 Maintenance Cost		\$24,359	(\$24,359)
Year 8 Maintenance Cost		\$25,089	(\$25,089)
Year 9 Maintenance Cost		\$25,842	(\$25,842)
Year 10 Maintenance Cost		\$26,617	(\$26,617)
10 Year Maintenance Cost	\$0	\$213,463	(\$213,463)
Total 10 Year Operation Cost	\$2,407,430	\$1,155,460	\$1,251,970
10 Year Cost of Ownership	\$2,407,430	\$1,395,460	\$1,011,970
Avg. Cost of ownership per year	\$240,743	\$139,546	\$101,197

Aircuity Energy Units and Energy Dollar Savings Detailed Comparison

Customer **Anywhere State University**
 Project **New Laboratory Building**
 City **Boston, Ma (Using weather data from Boston, Massachusetts)**
 Submitted by **Your Aircuity Rep**

	Base Design				Proposed Design				Savings							
Occ	Annual Occ Energy Units		Annual Occ Energy Costs		Total Annual Costs at Occ Average Flow		Annual Occ Energy Units		Annual Occ Energy Costs		Total Annual Costs at Occ Average Flow		Annual Occ Energy Units Saved		Annual Occ Energy Cost Savings	
		Cooling kWh	155,361	Cooling	\$ 17,090	\$ 4.66 per CFM		Cooling kWh	84,873	Cooling	\$ 9,336	\$ 3.83 per CFM		Cooling kWh	70,488	Cooling
	Heating Therms	2,188	Heating	\$ 2,188			Heating Therms	1,195	Heating	\$ 1,195			Heating Therms	993	Heating	\$ 993
	Reheat Therms	21,200	Reheat	\$ 21,200			Reheat Therms	4,142	Reheat	\$ 4,142			Reheat Therms	17,058	Reheat	\$ 17,058
	Heating kWh	-					Heating kWh	-					Heating kWh	-		
	Reheat kWh	-					Reheat kWh	-					Reheat kWh	-		
	Supply Fan kWh	160,669	Supply Fan	\$ 17,674	Cooling cost / CFM	\$ 1.03	Supply Fan kWh	51,523	Supply Fan	\$ 5,668	Cooling cost / CFM	\$ 1.03	Supply Fan kWh	109,146	Supply Fan	\$ 12,006
	Exhaust Fan kWh	177,474	Exhaust Fan	\$ 19,522	Heating cost / CFM	\$ 0.13	Exhaust Fan kWh	132,317	Exhaust Fan	\$ 14,555	Heating cost / CFM	\$ 0.13	Exhaust Fan kWh	45,157	Exhaust Fan	\$ 4,967
	Total kWh	493,503	Total	\$ 77,673	Reheat cost / CFM extr	\$ 2.26	Total kWh	268,713	Total	\$ 34,896	Reheat cost / CFM extra	\$ 2.26	Total kWh	224,790	Total	\$ 42,777
	Total Therms	23,388			Fan cost / CFM	\$ 2.23	Total Therms	5,337			Fan cost / CFM	\$ 2.22	Total Therms	18,050		
	Peak kW	401					Peak kW	219					Peak kW	182		
UnOcc	Annual Unocc Energy Units		Annual Unocc Energy Costs		Total Annual Costs at Unocc Average Flow		Annual Unocc Energy Units		Annual Unocc Energy Cost		Total Annual Costs at Unocc Average Flow		Annual Unocc Energy Units Saved		Annual Unocc Energy Cost Savings	
	Cooling kWh	170,302	Cooling	\$ 18,733	\$ 4.67 per CFM		Cooling kWh	59,132	Cooling	\$ 6,504	\$ 4.68 per CFM		Cooling kWh	111,170	Cooling	\$ 12,229
	Heating Therms	3,739	Heating	\$ 3,739			Heating Therms	1,298	Heating	\$ 1,298			Heating Therms	2,441	Heating	\$ 2,441
	Reheat Therms	38,950	Reheat	\$ 38,950			Reheat Therms	5,817	Reheat	\$ 5,817			Reheat Therms	33,132	Reheat	\$ 33,132
	Heating kWh	-					Heating kWh	-					Heating kWh	-		
	Reheat kWh	-					Reheat kWh	-					Reheat kWh	-		
	Supply Fan kWh	156,335	Supply Fan	\$ 17,197	Cooling cost / CFM	\$ 0.83	Supply Fan kWh	50,870	Supply Fan	\$ 5,596	Cooling cost / CFM	\$ 0.83	Supply Fan kWh	105,464	Supply Fan	\$ 11,601
	Exhaust Fan kWh	239,590	Exhaust Fan	\$ 26,355	Heating cost / CFM	\$ 0.17	Exhaust Fan kWh	157,781	Exhaust Fan	\$ 17,356	Heating cost / CFM	\$ 0.17	Exhaust Fan kWh	81,808	Exhaust Fan	\$ 8,999
	Total kWh	566,226	Total	\$ 104,974	Reheat cost / CFM extr	\$ 2.26	Total kWh	267,783	Total	\$ 36,572	Reheat cost / CFM extra	\$ 2.26	Total kWh	298,443	Total	\$ 68,402
	Total Therms	42,689			Fan cost / CFM	\$ 1.94	Total Therms	7,116			Fan cost / CFM	\$ 2.94	Total Therms	35,573		
	Peak kW	281					Peak kW	110					Peak kW	171		
Total	Annual Total Energy Units		Annual Total Energy Costs		Total Annual Costs at All Average Flows		Annual HVAC Total Energy Units		Annual Total HVAC Energy Costs		Total Annual Costs at All Average Flows		Annual Total Energy Units Saved		Annual Total Energy Cost Savings	
	Cooling kWh	325,663	Cooling	\$ 35,823	\$ 4.66 per CFM		Cooling kWh	144,005	Cooling	\$ 15,841	\$ 4.22 per CFM		Cooling kWh	181,658	Cooling	\$ 19,982
	Heating Therms	5,928	Heating	\$ 5,928			Heating Therms	2,494	Heating	\$ 2,494			Heating Therms	3,434	Heating	\$ 3,434
	Reheat Therms	60,149	Reheat	\$ 60,149			Reheat Therms	9,959	Reheat	\$ 9,959			Reheat Therms	50,190	Reheat	\$ 50,190
	Heating kWh	-					Heating kWh	-					Heating kWh	-		
	Reheat kWh	-					Reheat kWh	-					Reheat kWh	-		
	Supply Fan kWh	317,003	Supply Fan	\$ 34,870	Cooling cost / CFM	\$ 0.91	Supply Fan kWh	102,393	Supply Fan	\$ 11,263	Cooling cost / CFM	\$ 0.94	Supply Fan kWh	214,610	Supply Fan	\$ 23,607
	Exhaust Fan kWh	417,064	Exhaust Fan	\$ 45,877	Heating cost / CFM	\$ 0.15	Exhaust Fan kWh	290,099	Exhaust Fan	\$ 31,911	Heating cost / CFM	\$ 0.15	Exhaust Fan kWh	126,965	Exhaust Fan	\$ 13,966
	Total kWh	1,059,730	Total	\$ 182,647	Reheat cost / CFM extr	\$ 2.26	Total kWh	536,497	Total	\$ 71,467	Reheat cost / CFM extra	\$ 2.26	Total kWh	523,233	Total	\$ 111,179
	Total Therms	66,077			Fan cost / CFM	\$ 2.06	Total Therms	12,453			Fan cost / CFM	\$ 2.55	Total Therms	53,624		61%
	Peak kW	401					Peak kW	219					Peak kW	182		

Full CV Flow	Annual Energy Units		Annual Energy Costs		Total Annual Costs at Average Flow		Cooling (Plugs, Lights, etc.) Electrical Load Information		Cooling Load Energy Costs	
		Cooling kWh	387,995	Cooling	\$ 42,679	\$ 4.29 per CFM		Day Clg Load kWh	384,345	Day Clg Load
	Heating Therms	7,278	Heating	\$ 7,278			Nite Clg Load kWh	276,728	Nite Clg Load	\$ 30,440
	Reheat Therms	47,360	Reheat	\$ 47,360			Total Clg Load	661,073	Total Load	\$ 72,718
	Heating kWh	-					Peak Clg Load Kw	164		
	Reheat kWh	-								
	Supply Fan kWh	464,444	Supply Fan	\$ 51,089	Cooling cost / CFM	\$ 0.90				
	Exhaust Fan kWh	497,061	Exhaust Fan	\$ 54,677	Heating cost / CFM	\$ 0.15				
	Total kWh	1,349,500	Total	\$ 203,083	Reheat cost / CFM extr	\$ 1.36				
	Total Therms	54,638			Fan cost / CFM	\$ 2.23				

Aircuity Heat Recovery Energy Units & Energy Dollar Savings Detailed Comparison



October 29, 2010

Customer	Anywhere State University
Project	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

Baseline Metrics with Lab DCV Only (No Heat Recovery):

Annual Energy Units		Annual Energy Costs		Total Annual Costs	
Cooling kWh	144,785	Cooling	\$ 15,926	\$ 1.90 per CFM	
Heating Therms	18,854	Heating	\$ 18,854		
Reheat Therms	9,959	Reheat	\$ 9,959		
Heating kWh	-				
Reheat kWh	-				
Supply Fan kWh	108,619	Supply Fan	\$ 11,948	Costs per CFM	
Exhaust Fan kWh	162,721	Exhaust Fan	\$ 17,899	Cooling cost / CFM	\$ 0.41
Glycol Pump kWh	-	Glycol Pump	\$ -	Heating cost / CFM	\$ 0.48
Total kWh	416,124	Total	\$ 74,587	Reheat cost / CFM extra	\$ 0.29
Total Therms	28,813			Fan cost / CFM	\$ 0.76
Peak kW	220				

Proposed Metrics with Heat Recovery & Lab DCV:

Annual Energy Units		Annual Energy Costs		Total Annual Costs		Annual Energy Units Saved		Annual Energy Savings	
Cooling kWh	144,005	Cooling	\$ 15,841	\$ 3.95 per CFM		Cooling kWh	780	Cooling	\$ 86
Heating Therms	2,494	Heating	\$ 2,494			Heating Therms	16,360	Heating	\$ 16,360
Reheat Therms	9,959	Reheat	\$ 9,959			Reheat Therms	-	Reheat	\$ -
Heating kWh	-					Heating kWh	-		
Reheat kWh	-					Reheat kWh	-		
Supply Fan kWh	121,327	Supply Fan	\$ 13,346	Costs per CFM		Supply Fan kWh	(12,709)	Supply Fan	\$ (1,398)
Exhaust Fan kWh	189,402	Exhaust Fan	\$ 20,834	Cooling cost / CFM	\$ 0.94	Exhaust Fan kWh	(26,682)	Exhaust Fan	\$ (2,935)
Glycol Pump kWh	39,159	Glycol Pump	\$ 4,307	Heating cost / CFM	\$ 0.15	Glycol Pump kWh	(39,159)	Glycol Pump	\$ (4,307)
Total kWh	493,893	Total	\$ 66,781	Reheat cost / CFM extra	\$ 0.29	Total kWh	(77,769)	Total	\$ 7,806
Total Therms	12,453			Fan cost / CFM	\$ 0.72	Total Therms	16,360		10%
Peak kW	217					Peak kW	3		

Aircuity Savings Analysis Advanced Base Data & Assumptions



October 29, 2010

Customer Name	Anywhere State University
Project Name	New Laboratory Building
City	Boston, Ma (Using weather data from Boston, Massachusetts)
Submitted by	Your Aircuity Rep

High Hood Density (HHD) Room/Zone Assumptions

% of Hoods in HHD zones	0%
% of Total Zone Number that are HHD	0%
Avg HHD Zone Area as % of Avg Zone	100%

Metrics	All Zones	HHD Zones	Non-HHD Zones
Hoods	10	0	10
Zones	50	0	50
Area	700	700	700
Total sqft	35,000	0	35,000

Secondary Heat Recovery System Assumptions

Secondary HR Wheel/Wrap around Coil	None
Secondary HR Efficiency	60%
Secondary HR Pressure Drop in "WC	0.75 in.
Secondary HR Control Approach	Fixed Speed
Secondary HR Installed Price	\$ -
Secondary Annual HR Costs	\$ -

Advanced Primary Heat Recovery System Assumptions

Dry Bulb Change Over Temp	70 °F
HR Low Range Engage Temp	55 °F
Primary Wheel/Bypass Control Approach	Variable Speed
Primary "Sensible Only" HR Type	Glycol Coils
HR Lockout Control Approach	Diff Enthalpy
Average Exh/Sup Ratio %	90%

Other HVAC System Assumptions

Direct Evaporative Cooling Efficiency	90%
Direct Evap. Clg pressure Drop ("WC)	0.5 in.
Direct Evap Clg Outside Air Lockout Temp	60 °F

Return Air Temp Rise	2 °F
Chilled Beam Chilled Water COP Eff %	110%
Chilled Beam Pressure Drop	0.5 in.
Peak Elec Demand Calculation	Max Bin Method
CFM/Ton Peak Design Capacity %	99.50%

Other Fuel Type	Unlisted Fuel
Other Fuel Type lb CO2 / MMBtu Emissions	150.0
"Unlisted" Fuel lb CO2 / MMBtu Emissions	150

Return Air %	0%
Include Return Air in Base Design	No

Advanced Fan System Assumptions

Assumptions	Exhaust Fan	Supply Fan
Full Load Motor Efficiency	0.90	0.90
Full Load VFD Efficiency	0.965	0.965
Motor Oversize Factor	10%	10%

Use Design / Measured Data ?	No
------------------------------	----

Design / Measured Data

Motor Nameplate HP			(Not used)
Measured Motor KW			(Not used)
Peak Base Flow in CFM			(Not used)
OccAvgCFM Base Flow			(Not used)
UnOccAvgCFM Base Flow			(Not used)
Calc. Design Flow's BHP	65.2	61.2	Hp

Exhaust Fan Exit Velocity % Min	50%
---------------------------------	-----

Minimum Fan Power %	12.5%
---------------------	-------